

VEVAY WATER DEPARTMENT

Public Water Supply ID: IN5278002

Consumer Confidence Report

2025 CCR



Annual Drinking Water Quality Report

VEVAY WATER DEPARTMENT

Public Water System ID: IN5278002

We are pleased to present to you the Annual Water Quality Report (Consumer Confidence Report) for the year, for the period of January 1 to December 31, 2025. This report is intended to provide you with important information about your drinking water and the efforts made by the water system to provide safe drinking water. (Este informe contiene información muy importante sobre su agua potable. Tradúzcalo o hable con alguien que lo entienda bien).

For more information regarding this report, contact Vevay Town Hall at 812-427-3131.

If you are interested in attending one of our meetings to discuss any concerns or questions, the dates are as follows;

-4:30pm on July 7th, August 4th, September 1st, September 22nd, October 2nd, October 20th, November 3rd, November 17th, December 1st, and December 15th at the address of 305 Walnut Street.

Sources of Drinking Water

VEVAY WATER DEPARTMENT is Ground water.

Our water source(s) and source water assessment information are listed below:

Source Name	Type of Water	Report Status	Location
WELL #1	Ground water	Active	Treatment Plant
WELL #2	Ground water	Active	Treatment Plant
WELL #4	Ground water	Active	Treatment Plant

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

A service line inventory has been prepared and can be accessed at the web address - <https://idem.120water-ptd.com/>

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (800) 426-4791. Contaminants that may be present in source water include:

Microbial Contaminants - such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

Inorganic Contaminants - such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming.

Pesticides and Herbicides - which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.

Organic Chemical Contaminants - including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.

Radioactive Contaminants - which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Some people may be more vulnerable to contaminants in drinking water than the general population.

Contaminants may be found in drinking water that may cause taste, color, or odor problems. These types of problems are not necessarily causes for health concerns. For more information on taste, odor, or color of drinking water, please contact the system's business office.

Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

There is no safe level of lead in drinking water. Exposure to lead in drinking water can cause serious health effects in people of all ages, especially pregnant people, infants (both formula-fed and breastfed), and young children. Lead in drinking water is primarily from materials and parts used in service lines and in home plumbing. VEVAY WATER DEPARTMENT is responsible for providing high quality drinking water and removing lead pipes but cannot control the variety of materials used in the plumbing in your home. Because lead levels may vary over time, lead exposure is possible even when your tap sampling results do not detect lead at one point in time. You can help protect yourself and your family by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Using a filter, certified by an American National Standards Institute accredited certifier to reduce lead, is effective in reducing lead exposures. Follow the instructions provided with the filter to ensure the filter is used properly. Use only cold water for drinking, cooking, and making baby formula. Boiling water does not remove lead from water. Before using tap water

Our water system tested a minimum of 2 sample(s) per month in accordance with the Total Coliform Rule for microbiological contaminants. With the microbiological samples collected, the water system collects disinfectant residuals to ensure control of microbial growth.

Disinfectant	Date	Highest RAA	Unit	Range	MRDL	MRDLG	Typical Source
CHLORINE	2025	0	ppm	0.42 - 0.53	4	4	Water additive used to control microbes

Regulated Contaminants

In the tables below, we have shown the regulated contaminants that were detected. Chemical Sampling of our drinking water may not be required on an annual basis; therefore, information provided in this table refers back to the latest year of chemical sampling results.

Unregulated Contaminant Monitoring Rule (UCMR) Collection Date of HV
 Highest Value (HV) Range of Sampled Result(s) Unit

Lead and Copper (low - high)	Period	90TH Percentile: 90% of your water utility levels were less than	Range of Sampled Results
	Unit	AL Sites Over AL Typical Source	
COPPER, FREE	2022 - 2024	0.311 0.008 - 0.513 ppm	1.3 0 Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
LEAD	2022 - 2024	2.45 0 - 7.56 ppb	15 0 Corrosion of household plumbing systems; Erosion of natural deposits

Disinfection Byproducts	Sample Point	Period	Highest LRAA	Range	Unit	MCL	MCLG	Typical Source
TOTAL HALOACETIC ACIDS (HAA5)	707 HWY 56	2025	0	0	ppb	60	0	By-product of drinking water disinfection
TOTAL HALOACETIC ACIDS (HAA5)	723 E MAIN ST	2025	6	6.49	ppb	60	0	By-product of drinking water disinfection
TTHM	707 HWY 56	2025	0	0	ppb	80	0	By-product of drinking water chlorination
TTHM	723 E MAIN ST	2025	13	13	ppb	80	0	By-product of drinking water chlorination

Regulated Contaminants	Collection Date	Highest Value	Range	Unit	MCL	MCLG	Typical Source
1,1,1-TRICHLOROETHANE	8/9/2023	0.656	0.656	ppb	200	200	Discharge from metal degreasing sites and other factories
BARIUM	8/9/2023	0.046	0.046	ppm	2	2	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
FLUORIDE	8/9/2023	0.149	0.149	ppm	4	4	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
NITRATE	12/2/2025	3.64	3.64	ppm	10	10	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits

Radiological Contaminants	Collection Date	Highest Value	Range	Unit	MCL	MCLG	Typical Source
GROSS ALPHA, EXCL. RADON & U	6/21/2022	1.46	1.46	pCi/L	15	0	Erosion of natural deposits
RADIUM-228	6/21/2022	0.316	0.316	PCI/L	5	0	Erosion of natural deposits

Violations

During the period covered by this report we had the below noted violations.

Violation Period	Analyte	Violation Type	Violation Explanation
10/1/2025 - 10/10/2025	CONSUMER CONFIDENCE RULE	CCR ADEQUACY/AVAILABILITY/CONTENT	Inadequate Consumer Confidence Report (CCR) or failure to deliver a CCR Certification form to the state on time

There are no additional required health effects notices.

There are no additional required health effects violation notices.